



## ADDENDUM TO THE CONTRACT

for the

### TWIN LAKES LIFT STATION REPLACEMENT PROJECT

Contract No. E12-059

**ADDENDUM NO.:** ONE

**CURRENT DEADLINE FOR BIDS:**  
August 23, 2011

**PREVIOUS ADDENDA:** NONE

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**DATE ADDENDUM ISSUED:** July 22, 2011

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. If this fax is incomplete, please call (907) 586-0490, and we will re-send it. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:  
<http://www.juneau.org/engineering ftp/contracts/Contracts.php>

#### **PROJECT MANUAL:**

- Item No. 1: SECTION 00030 NOTICE INVITING BIDS, DEADLINE FOR BIDS, **Change** the bid opening location from Room 224 of the Municipal Building, 155 S. Seward Street **to** the Assembly Chambers of the Municipal Building, 155 S. Seward Street.
- Item No. 2: SPECIAL PROVISIONS, SECTION 01010 – SECTION 01025 MEASUREMENT AND PAYMENT, PART 1 – GENERAL, Article 2.11 TWIN LAKES LIFT STATION, paragraph C. **Change** Hospital Drive Lift Station **to read** Twin Lakes Lift Station.
- Item No. 3: **Add** attached SECTION 16010 ELECTRICAL SCOPE OF WORK, labeled Addendum No. 1 and dated July 22, 2011.

By: 

Jennifer Mannix  
Contract Administrator

Date: July 22, 2011

## **SECTION 16010 ELECTRICAL SCOPE OF WORK**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. The scope of electrical work for this project includes demolishing portions of the existing building interior and electrical systems as shown on the and providing the electrical system of the Twin Lakes Lift Station in Juneau, Alaska.
- B. The scope of work includes providing 1-1/2" rigid foam insulation between the roof trusses and providing a new 5/8" gypsum board ceiling on the bottom of the trusses, with fire tape, texture and paint. All necessary framing needed to install the foam and gypsum board shall be provided.
- C. The electrical work includes providing the power, lighting, and pump controls for the Twin Lakes Lift Station. The lift station includes a portable generator receptacle, automatic transfer switch and associated controls and equipment, lighting, electrical service and pump controls with associated equipment.
- D. The electrical work includes a portable standby generator in an enclosure mounted on a trailer.
- E. Replacement and repair of damaged concrete masonry unit (CMU) blocking as shown on the plans.
- F. All work shown on the electrical drawings and included in Division 16 of these specifications shall be provided.

**END OF SECTION**