



ADDENDUM TO THE CONTRACT

for the

Auke Bay Elementary School Renovation

Contract No. E12-042

ADDENDUM NO.: FIVE

CURRENT DEADLINE FOR BIDS:
February 8, 2012

PREVIOUS ADDENDA: FOUR

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: February 3, 2012

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

PROJECT MANUAL – Volume III:


1. Section 00030 – Deadline for Bids: **Change** the location where bids will be opened **from** the CBJ Assembly Chambers **to** the Downtown Library Conference Room, located at 292 Marine Way, 4th floor, above the parking garage. The location for receiving bids **does not change** with this addendum.

PROJECT MANUAL – Volume IV:

2. Section 28311 DIGITAL, ADDRESSABLE FIRE-ALARM SYSTEM, 2.7.A.: **Revise** paragraph to read, "General Requirements for Notification Appliances: Connected to notification appliance signal circuits, zoned as indicated, equipped for mounting as indicated and with screw terminals for system connections."

DRAWINGS – Volume I:

3. Regarding Item 7 on Addendum No. 4 - **Correction:** Sheet AD400 series: **Replace** Keynote 426f with Keynote 426b.
4. Sheet A804 Details 2 & 4: **Delete** GWB from underside of structure. GWB not needed typically at roof structure except where called out specifically in the drawings.

By: 
Jennifer Mannix,
Contract Administrator

Date: February 3, 2012

Total number of pages contained within this Addendum: 1