



ADDENDUM TO THE CONTRACT

for the

STATTER HARBOR MOORAGE IMPROVEMENTS

Contract No. DH11-177

ADDENDUM NO.: FOUR

CURRENT DEADLINE FOR BIDS:
April 17, 2012

PREVIOUS ADDENDA: THREE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

PREVIOUS DEADLINE FOR BIDS:
April 17, 2012

DATE ADDENDUM ISSUED: April 13, 2012

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:
<http://www.juneau.org/engineering ftp/contracts/Contracts.php>

VOLUME 1:

Item No. 1 Section 00100 – Instructions to Bidders, ***delete*** Article 21 and ***replace with*** the following:

21.0 CONTRACTOR'S GOOD STANDING WITH CITY FINANCE DEPARTMENT:
CONTRACTORS and Subcontractors must be in good standing with the City prior to award, and prior to any contract renewals, and in any event no later than ***ten business days*** following notification by the City of intent to award. **Good standing** means: all amounts owed to the City are paid in full or a Confession of Judgment has been executed and the Contractor or Subcontractor is in compliance with the terms of any stipulation associated with the Confession of Judgment, including being current as to any installment payments due. Failure to meet these requirements may be cause for rejection of your bid. To determine if your business is in good standing, or for further information, contact the City Finance Department's Sales Tax Division at (907) 586-5265 for sales tax issues or Collections Division at (907) 586-5268 for all other accounts.

VOLUME 2:

Item No. 2 DRAWING SHEET E2.05, 13 of 25, SINGLE LINE DIAGRAM: "Detail 1 PARTIAL SINGLE LINE DIAGRAM":

Change Substation SA primary feeder as follows: Provide (2) 4C No. 1/0 Type W in lieu of (2) 5C No. 1/0 Type W indicated in the bid documents.

By: _____

Jennifer Mannix,
Contract Administrator

Date: 4/13/12

Total number of pages contained within this Addendum: 1