



**ADDENDUM to the REQUEST FOR PROPOSALS  
Integration and Programming Services for Wastewater  
Utility SCADA System Software Platform Consolidation  
(C3) RFP No. E12-244**

**ADDENDUM NO.: ONE**

**CURRENT DEADLINE FOR PROPOSALS:  
May 25, 2012**

**PREVIOUS ADDENDA: NONE**

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**PREVIOUS DEADLINE FOR PROPOSALS:  
May 24, 2012**

**DATE ADDENDUM ISSUED: May 18, 2012**

The following items of the contract are modified as herein indicated. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:  
<http://www.juneau.org/engineering ftp/contracts/Contracts.php>

Item No. 1: Page 2 – Deadline for Proposals. **Change** the proposal due date **from** May 24, 2012 **to** May 25, 2012.

Item No. 2: Section 1.2 Scope of Services, end of section, delete the "Project Budget" in its entirety.

**Information Item**

A list of questions and CBJ's response is attached to this addendum for informational purposes.

Receipt of this addendum must be acknowledged or your proposal may be considered non-responsive. Acknowledge the addendum in the submitted proposal.

By: \_\_\_\_\_

Jennifer Mannix,  
Contract Administrator

Date Issued: 5/18/12

Questions from Proposer  
Integration and Programming Services for Wastewater Utility SCADA System  
Software Platform Consolidation  
RFP E21-244

Below is a list of questions from an interested firm. In the interest of fairness, we are sharing the answers in red below with all interested proposers. Questions associated with ABWWTP, and the Wastewater Collection Lift Station areas should be addressed after the contract is awarded, since there are various ways to accomplish our station and plant communication goals and we feel that it would be best to have a professional look at what we have, and present to us some options to effectively complete this task.

- MWWTP
  - Do both existing PCs have Win-911 installed? **Yes**
  - What version of Win-911 is installed on each?
  - Do both existing PCs have Dialogic telephony cards? **Yes**
  - What interface are the existing Dialogic cards (PCI, PCI-Express, USB, etc)?
  - Are all installed PLCs Allen-Bradley PLC 5 series? **Yes**
  - What is the communications media and protocol between the existing PC and PLC equipment? **Ethernet, DH+**
  - Shall both new PCs have PC Anywhere installed? **Yes**
  - What is the scope of data logging and reporting functionality to be replaced?
- JDWWTP
  - Do both existing PCs have Win-911 installed? **No**
  - What version of Win-911 is installed on each? **Win911/Pro**
  - Do both existing PCs have Dialogic telephony cards? **No**
  - What interface are the existing Dialogic cards (PCI, PCI-Express, USB, etc)? **API**
  - Are all installed PLCs Allen-Bradley PLC 5 series? **PLC5's and one SLC-500**
  - What is the communications media and protocol between the existing PC and PLC equipment? **Ethernet, DH+**
  - Shall both new PCs have PC Anywhere installed? **No**
  - What is the scope of data logging and reporting functionality to be replaced?
- ABWWTP
  - Regarding the Allen-Bradley MicroLogix 1100 PLC to be installed.
    - Is there an existing panel to which this PLC shall be installed?
    - Please elaborate on the scope of PLC installation.
    - Shall programming software supporting this device be included. One of the following shall be required.
      - RSLogix500 programming software

- RSLogix Micro programming software
  - Is installation of Ethernet networking equipment from the PLC to PC location included in this scope?
- Wastewater Collections Lift Station
  - At each of the following sites, are all installed PLCs Allen-Bradley PLC 5 series?
    - ~~Wastewater Collections Lift Station~~
    - Outer Drive
    - Lemon A
    - West Juneau
  - What is the communications media and protocol between the existing Wastewater Collections Lift Station PC and PLC equipment at each of the following sites?
    - Outer Drive
    - Lemon A
    - West Juneau
  - Shall the PCs have PC Anywhere installed?
  - What is the scope of data logging and reporting functionality to be replaced?
- How many users will be concurrently editing screens using FactoryTalk ViewStudio SE ? **One**
  - If a single developer is to be editing screens at a time, one license can be shared across multiple networked systems. The software can physically be installed on every station if desired.
- Will Microsoft Office be installed on the new PCs? If so, what version?
  - Will the new PCs be members of an existing windows domain?