



**ADDENDUM TO THE CONTRACT  
for the**

**Auke Bay Fire Station Exterior Upgrade  
Contract No. E12-094**

**ADDENDUM NO.: TWO**

**CURRENT DEADLINE FOR BIDS:  
May 24, 2012**

**PREVIOUS ADDENDA: ONE**

**ISSUED BY: City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801**

**PREVIOUS DEADLINE FOR BIDS:  
May 23, 2012**

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:

[http://www.juneau.org/engineering\\_ftp/contracts/Contracts.php](http://www.juneau.org/engineering_ftp/contracts/Contracts.php)

**PROJECT MANUAL:**

Item No. 1 Section 00030 - Notice Inviting Bids, Deadline For Bids.

**Change** the date of the Deadline for Bids **from** May 23, 2012 **to** May 24, 2012. The time remains the same.

Item No. 2 Section 074213 – Metal Wall Panels, Article 2.02, Manufactured Metal Panels. Paragraph C.3. **Add** the following sentence: "Color to match wall panel profile B color."

Item No. 3 Section 081113 – Hollow Metal Doors and Frames, Article 2.06, Finish materials. **Add** the following Paragraphs B & C:


"B. Intermediate Coat: Quick-drying enamel matching topcoat.

"C. Topcoat: Quick-drying enamel, high-gloss. Impervex Latex High Gloss Enamel by Benjamin Moore."

**DRAWINGS:**

Item No. 4 Drawing A203, North Elevation. **Add** arrows and a note reading "23" to the jamb and head of the recessed panel to the east of the center apparatus bay door.

Item No. 5 Drawing A302. Detail 1 "Window Head". **Add** the following note: "All hardwood trim to be Paint Grade. Finish with Prime coat of Interior Latex Primer/Sealer (Basis-of-Design: Benjamin Moore Eco Spec WB Interior Latex Primer 372), and two top coats of Interior Latex, semi-gloss (Basis-of-Design: Benjamin Moore Eco Spec WB Interior Latex 376)."

By:   
Jennifer Mannix,  
Contract Administrator

Date: 5/27/12

Total number of pages contained within this Addendum: 1