



ENGINEERING DEPARTMENT

**ADDENDUM TO THE CONTRACT
for the
JNU SREF Site Infrastructure**

Contract No. E12-280

ADDENDUM NO.: FOUR

CURRENT DEADLINE FOR BIDS:

July 12, 2012

PREVIOUS ADDENDA: THREE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: July 11, 2012

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at:

<http://www.juneau.org/engineering ftp/contracts/Contracts.php>

PROJECT MANUAL

Item No. 1 Section 00030 – Notice Inviting Bids. **Delete** last paragraph – Standard Specifications, and replace with the following:

STANDARD SPECIFICATIONS. The Standard Specifications for Civil Engineering Projects and Subdivision Improvements, December 2003 with twelve Errata Sheets, as published by the City and Borough of Juneau, may be part of these Contract Documents and may pertain to all phases of the contract, if referenced within the Contract Documents. This document is available for a fee from the City and Borough of Juneau Engineering Contracts Office, (907) 586-0490, or you may view it on line at: www.juneau.org/engineering.

Item No. 2 Section 00800 – Supplementary General Conditions, SGC 1 DEFINITIONS, **modify** the definition for Contract Documents by deleting “Standard Specifications” and inserting the following after “Drawings”: “Standard Specifications (if applicable).”

DRAWINGS


Item No. 1 Sheet C-003 – Typical Sections & Details (re-issued with Addendum No. 1).

Note 2, detail 4. **Replace** “a link seal modular seal” with “Kor-N-Seal.”

Note 6, detail 4. **Delete and replace** with the following: “Pumps and control Systems are not included as part of this project.”

Add note 7, detail 7: “Grouting around pump as shown at bottom of wet well is not included as part of this project.”

Item No. 2 Sheet C010 – Sewer Plan & Profile (re-issued with Addendum No. 1). **Add** Note 2: “Terminate and cap Sch 80 PVC conduits outside wet-well for connection under future project.”

By: 
Jennifer Mannix,
Contract Administrator

Total number of pages contained within this Addendum: 1