



ADDENDUM TO THE CONTRACT
for the
LAWSON CREEK LIFT STATION
REPLACEMENT PROJECT

Contract No. E13-243

ADDENDUM NO.: FOUR

**CURRENT BID OPENING DATE:
May 16, 2013**

PREVIOUS ADDENDA: THREE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: May 14, 2013

The following items of the Contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. If this fax is incomplete, please call (907) 586-0490, and we will re-send it. This addendum has been issued and is posted online. <http://www.juneau.org/engineering ftp/contract/Contracts.php>


DRAWINGS:

Item No. 1 DRAWING E-5, SHEET 13 of 18 - NEW BUILDING FLOOR PLAN, EQUIPMENT SCHEDULE, No. 4. **Delete** the sentences:

“Provide extruded aluminum insulated blades in an aluminum frame. The damper shall have a minimum R value of 2.25. Tamco series 8000. Blade type PB.”

And replace with the following:

“Provide aluminum back draft damper blades in an aluminum frame with self-lubricating celcon bearings. TAMCO Series 7000 or equal.”

By: 
Jennifer Mannix, Contract Administrator

Total number of pages contained within this Addendum: 1