ENGINEERING DEPARTMENT

ADDENDUM TO THE CONTRACT

for the

Cope Park Improvements, Phase I
Contract No. E13-279

ADDENDUM NO.: **TWO**

CURRENT DEADLINE FOR BIDS:
September 24, 2013

PREVIOUS ADDENDA: **ONE**

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: **September 20, 2013**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: http://www.juneau.org/engineering_ftp/contracts/Contracts.php

DRAWINGS

Item No.1 Drawing C402 ***Revise*** all references to 2" O.D. colored top and bottom rail to 1-5/8" O.D. colored top and bottom rail.

Item No. 2 Drawing C402, ***Add*** the following note:

9. Colored top and bottom rail pipe shall be polymer coated pipe. Polymer coated pipe shall have a Polyolefin coating fused and adhered to the exterior zinc coating of the galvanized pipe in accordance with ASTM F1043. The minimum thickness of the Polyolefin coating shall be 10-mils. Color to be black.

By: _____
Jennifer Mannix,
Contract Administrator

Total number of pages contained within this Addendum: 1