



ENGINEERING DEPARTMENT

ADDENDUM TO THE CONTRACT

for the

Last Chance Basin Well Field Generator Replacement Contract No. E14-112

ADDENDUM NO.: FOUR

CURRENT DEADLINE FOR BIDS:

June 20, 2014

PREVIOUS ADDENDA: THREE

ISSUED BY:

City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED:

June 13, 2014

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

PROJECT MANUAL:

- Item No. 1: SECTION 00100 – INSTRUCTIONS TO BIDDERS, Article 17 – AWARD OF CONTRACT, Paragraph C. **Delete** in its entirety.
- Item No. 2: SECTION 00310 – BID SCHEDULE. **Delete** in its entirety and **replace** with the attached SECTION 00310 – BID SCHEDULE, labeled Addendum No. 4.
- Item No. 3: SECTION 235100 – GENERATOR PIPING, PART 3 – EXECUTION, Article 3.01 – INSTALLATION, Paragraph B – Engine Exhaust, Subparagraph 3. **Delete** in its entirety and **replace** with the following:
- “3. Insulate rigid generator exhaust piping and silencer with 2-inch calcium silicate with aluminum covering meeting ASTM E84. Insulate flexible generator exhaust piping with 2-inch removable blanket wrap, with hook fasteners, aluminized outer layer, and 1200F maximum operation temperature meeting ASTM E84.”
- Item No. 4: SECTION 263213 – ENGINE GENERATORS, PART 1 – GENERAL, Article 1.2 – SUMMARY, Subparagraph 1.a.1). **Delete** in its entirety and **replace** with the following:
- “1.a.1) Generator to be New.”
- Item No. 5: SECTION 263213 – ENGINE GENERATORS, PART 1 – GENERAL, Article 1.2 – SUMMARY, Subparagraph 1.a.3). **Delete** in its entirety.

NOTE: Delete all references in the plans and specifications to “refurbished” generator.

By: _____


Greg Smith,
Contract Administrator

SECTION 00310 - BID SCHEDULE

Bid Schedule for construction of **E14-112 named Last Chance Basin Well Field Generator Replacement**, in accordance with the Contract Documents.

TOTAL BID - Furnish all labor, equipment and materials to remove two electrical generators and replace with a single new 400 kW Genset generator, and perform all WORK as described in these Contract Documents.

TOTAL BID \$ _____
(Price in Figures)

Date: _____ **Bidder:** _____
(Company Name)

END OF SECTION