



ADDENDUM TO THE CONTRACT

for the

**JNU Concessions Expansion
Contract No. E15-195**

ADDENDUM NO.: FOUR

**CURRENT DEADLINE FOR BIDS:
April 7, 2015**

PREVIOUS ADDENDA: THREE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: April 2, 2015

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

PROJECT MANUAL:

Item No. 1 SECTION 238100 - WATER TO AIR HEAT PUMPS, PART 1 – GENERAL, Article 1.5 – QUALITY ASSURANCE. **Add** the following Paragraph D:

“D. Start-up: Qualified technician to provide start-up and testing of heat pump operation. Factory technical representative shall be available on the phone during all start-up procedures to provide assistance and troubleshooting.”

Item No. 2. SECTION 238100 - WATER TO AIR HEAT PUMPS, PART 3 – EXECUTION, Article 3.4 – OWNER’S PERSONNEL INSTRUCTION, Paragraph A.

Replace “water source heat pump manufacturer’s technical representative” in first sentence with “Qualified technician”. **Replace** “Factory technician” in last sentence with “Qualified technician”.

Item No. 3. SECTION 238100 - WATER TO AIR HEAT PUMPS, PART 3 – EXECUTION, Article 3.6 – FIELD QUALITY CONTROL, Paragraph B, sub-paragraph 4.

Replace “factory trained field representative authorized by and to represent the equipment manufacturer” in first sentence with “Qualified technician”.

By: 
Greg Smith,
Contract Administrator