ENGINEERING DEPARTMENT

ADDENDUM TO THE CONTRACT

for the

Juneau Downtown Firehall Dormitory Renovations
Contract No. E16-077

ADDENDUM NO.: **ONE**

CURRENT DEADLINE FOR BIDS:
November 17, 2015

PREVIOUS ADDENDA: **NONE**

ISSUED BY:

City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: **November 3, 2015**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: http://www.juneau.org/engineering_ftp/contracts/Contracts.php

PROJECT MANUAL:

Item No. 1 **PRE-BID CONFERENCE, *Change*** the meeting place ***to*** the Juneau Downtown Fire Station in the CCFR training classroom at 820 Glacier Ave., Juneau, AK, the date and time remain the same.

DRAWINGS:

Item No. 2 **CLARIFICATION: Electrical drawing Sheet E001**

Hallway luminaires are all Type A unless otherwise noted (refer to Legend on E001). Types B1 and B2 are shown in the stairwells.

The Type C luminaires are only in the bathrooms. Equip these with the standard driver (600 lumens/foot, dimming [though not required]), 3000°K, standard switching control (three-way), standard satin lens, aluminum paint finish, no other options.

By: _____
Greg Smith,
Contract Administrator

Total number of pages contained within this Addendum: 1