



ADDENDUM TO THE CONTRACT

for the

**Bartlett Regional Hospital (BRH)
Operating Room (OR) Ventilation Upgrades
Contract No. E16-095**

ADDENDUM NO.: ONE

**CURRENT DEADLINE FOR BIDS:
February 1, 2016**

PREVIOUS ADDENDA: NONE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: January 28, 2016

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

DRAWINGS:

MECHANICAL:

Item No. 1 DRAWING SHEET M0.1 - EQUIPMENT SCHEDULE.

Air/Dirt Separator, AS-1: **Change** "2 inch" size **to read** "2-1/2 inch". **Change** "VDR-200" design model **to read** "VDT-250".

By: 
Greg Smith,
Contract Administrator

Total number of pages contained within this Addendum: 1