



for the

**Contract No. E16-096**

**CURRENT DEADLINE FOR BIDS:**  
**February 16, 2016**

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineeringftp/contracts/Contracts.php>

Item No. 1      SECTION 02801 ASPHALT CONCRETE PAVEMENT, PART 2 – PRODUCTS,  
Article 2.3, ASPHALT MATERIALS, **Delete** Paragraph B and **replace** with the  
following:

B.      1. Asphalt cement shall be SHRP Performance Graded Binder PG 58-28  
PLUS.

2. Meet AASHTO M 320 and the following requirement:

a. Elastic Recovery (AASHTO T 301) 50% minimum

By: Carey Smith  
Greg Smith,  
Contract Administrator