ENGINEERING DEPARTMENT

ADDENDUM TO THE CONTRACT

for the

Douglas Harbor Renovation

Contract No. DH16-001

ADDENDUM NO.: **THREE**

CURRENT DEADLINE FOR BIDS:
February 17, 2016

PREVIOUS ADDENDA: **TWO**

ISSUED BY:

City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: **February 12, 2016**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: http://www.juneau.org/engineering_ftp/contracts/Contracts.php

PROJECT MANUAL:

Item No. 1 SECTION 00100 – INSTRUCTIONS TO BIDDERS, Article 17.0 – AWARD OF CONTRACT, Paragraph C, Addendum 2. ***Change*** the first sentence to read:

"C. Low Bidder will be determined on the basis of the lowest total of the Base Bid plus Alternate A or B, if funding allows, as selected by the Selection Committee through the process described below."

Item No. 2 SECTION 00100 – INSTRUCTIONS TO BIDDERS, Article 22.0 – PERMITS AND LICENSES. ***Add*** the following:

"A. PERSONNEL CERTIFICATIONS.

1. Diver Certifications

a. Project reference list, including the name and location of the project, references with contact information, number of pile locations protected, range of typical elevations required, and size of piles.
b. Proof of Insurance
c. Diver qualifications and skills competency of the proposed dive crew members including the following:
i. Association of Diving Contractors International (ADCI) card equal or greater than the position in which they are assigned, or OSHA or Coast Guard equivalent.

ii. Current American Red Cross First Aid and CPR Cards
iii. AWS D3.6M:2010 welding certification or equivalent if underwater welding is performed

d. Supervisor qualifications, including proof of 5 years in a supervisory role.

B. DIVING SERVICES DEPLOYMENT PLAN

1. Work procedures
2. Schedule
3. Suitable Weather Criteria
4. Communication Plan
5. Safety Plan
   a. Emergency Response Plan
   b. Local specialty medical providers

Item No. 3 SECTION 00800 – SUPPLEMENTARY GENERAL CONDITIONS, SGC 5.2 – INSURANCE AMOUNTS, Paragraph F. ***Add*** the following:

"This coverage is required for any in-water work performed on a marine vessel. This coverage may be provided by the Prime Contractor or the Subcontractor if the Subcontractor is contracted to do the in-water work on a marine vessel."

DRAWINGS:

Item No. 4 SHEET E2.05 – SINGLE LINE DIAGRAMS, Detail 1 - SINGLE LINE DIAGRAM - NEW. ***Add*** Note 3.

"3. CIRCUIT BREAKERS IN PANEL B FOR THE HEAT TRACE PEDESTALS AND LIGHTING SHALL BE GFCI (30 mA)."

By: _____
Greg Smith,
Contract Administrator

Total number of pages contained within this Addendum: 2