



ADDENDUM TO THE CONTRACT

for the

CAPITAL TRANSIT FACILITY RENOVATION AND ADDITION

Contract No. E16-016

ADDENDUM NO.: FIVE

CURRENT DEADLINE FOR BIDS:
April 5, 2016

PREVIOUS ADDENDA: FOUR

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: April 1, 2016

The following items of the contract are modified as herein indicated. All other items remain the same. This is a faxed addendum. A confirming copy will not be mailed to you. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

DRAWINGS:

- Item No. 1 SHEET M002 - FUEL EQUIPMENT SCHEDULE, **add** to OT-1 and OT-2 the following; "UL 2085 STANDARD FOR INSULATED SECONDARY CONTAINMENT ABOVE GROUND TANK."
- Item No. 2 SHEET M101 – At OT-1 and OT-2 **add** note; "INSTALL FUEL TANK 5 FEET MINIMUM FROM BUILDING."

By: 
Greg Smith,
Contract Administrator