



ADDENDUM TO THE CONTRACT

for

DOWNTOWN SEAWALK – BRIDGE TO GOLD CREEK, PHASE III

Contract No. E16-128

ADDENDUM NO.: TWO

CURRENT BID OPENING DATE:

October 13, 2016
2:00 p.m. Local Time

PREVIOUS ADDENDA: ONE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

PREVIOUS BID OPENING DATE:
October 11, 2016

DATE ADDENDUM ISSUED: **October 7, 2015**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: http://www.juneau.org/engineering_ftp/contracts/Contracts.php

INFORMATION ITEMS:

Special Provisions, pp. 23 and 24, Articles 01025-2.37 and 01025-2.38.

Fence shown on civil drawings is called out as 4'-0" black chain link fencing and is paid under Pay Item 2821.1, CHAIN-LINK FENCE, which does not include "wood assemblies related to hand rail as shown on the Drawings".

Island Fence shown on architectural drawings is shown as 3'-0" high with a cedar top rail and is paid under Pay Item 2821.2, ISLAND FENCE, which does include "wood assemblies related to hand rail as shown on the Drawings".

PROJECT MANUAL:

Item No. 1: SECTION 00030 – NOTICE INVITING BIDS, DEADLINE FOR BIDS. **Change** the date of the deadline for bids **from** October 11, 2016, **to** October 13, 2016. The time remains the same. **Change** the place for opening bids **from** the Assembly Chambers **to** Room 224 of the Municipal Building.

SPECIAL PROVISIONS:

Item No. 2: SECTION 01025 - MEASUREMENT AND PAYMENT, PART 2 – DIVISION TWO PAY ITEMS, Article 2.39 – SITE FURNISHINGS (PAY ITEM NO. 2870.1) PRICE BASED ON LUMP SUM PAY UNIT, Paragraph B. **Add** the following:

"The bid price for Pay Item No. 2870.1 shall be based on the following items and quantities:

- (14) Freestanding Benches Type A
- (16) Curved Freestanding Benches Type B
- (5) Tables Type A
- (20) Chairs Type A
- (6) Trash Receptacles
- (2) Bike Racks
- (9) Bollards
- (5) Removable Bollards
- (3) Whale Tail Benches"

Item No. 3: SECTION 01025 - MEASUREMENT AND PAYMENT, PART 2 – DIVISION TWO PAY ITEMS, Article 2.42, - SITE FURNISHINGS, PICNIC SHELTER (PAY ITEM NO. 2870.4-1) PRICE BASED ON LUMP SUM PAY UNIT, Paragraph B. **Add** the following:

"The bid price for Pay Item No. 2870.4-1 shall be based on the following items and quantities:

- (2) Type B Picnic Tables
- (2) Type C Picnic Tables
- (1) Multi-level Park & Camp Grill
- (1) Trash Receptacle"

Item No. 4: SECTION 01025 - MEASUREMENT AND PAYMENT, PART 3 – DIVISION THREE PAY ITEMS, Article 3.2 – CAST IN PLACE CONCRETE, SEATWALLS (PAY ITEM NO. 3300.2) PRICE BASED ON QUANTITY, LUMP SUM, Paragraph A. **Add** the following:

"The bid price for Pay Item No. 3300.2 shall include furnishing and installing (15) bench tops as specified in Section 02870."

Item No. 5: SECTION 02515 - MASONRY UNIT PAVING, PART 2 – PRODUCTS, Article 2.1 – CONCRETE UNIT PAVERS, Paragraph A. **Add** the following:

"Nominal dimensions are specified for pavers. Actual dimensions for specified pavers are less than nominal dimensions."

Item No. 6: SECTION 03303 - SIDEWALK, CURB AND GUTTER, PART 2 – PRODUCTS, Article 2.1 – MATERIALS, Paragraph D. **Delete** in its entirety, and **replace** with the following:

"D. Colored concrete materials:

Finish for colored concrete areas shall be a color hardener and sealer. See Drawings for extent of colored concrete area.

1. Submittals prior to installation:


- a. Concrete contractor shall provide five (5) project examples of previous experience with color concrete finish work including the color hardener applications.
- b. Concrete contractor shall submit certification of training in the application of color hardener.

- c. Concrete sample of each color specified and up to 6 additional color samples as may be requested by the Engineer for acceptance.
 - d. Concrete placement plan that illustrates plaza paving and joint pattern for Engineer approval prior to concrete placement.
2. Color Hardener:
- a. Lithochrome Concrete Color Hardener as manufactured by L.M. Scofield Company, or approved equal. Lithochrome color hardener shall conform to ASTM 979.
 - b. Colors to match Pantone colors specified on Drawings, or as directed by Engineer.
3. Colored Concrete Sealer:
- a. Seal final hardened surface with masonry paver sealer specified in Section 02515- Masonry Unit Pavers.”

Item No. 7: Section 03303 - SIDEWALK, CURB AND GUTTER, PART 3 – EXECUTION, Article 3.1 – METHODS OF CONSTRUCTION, Paragraph K. **Delete** in its entirety, and **replace** with the following:

“K. *Colored Concrete*

4. Color Hardener:
- a. Apply Concrete Color Hardener according to manufacturer’s recommendation and as indicated on the Drawings.
 - b. Hardener to be applied while concrete is curing per manufacturer’s recommended procedures.
 - c. Minimum coverage rate: 100 lbs per 100 square feet.
 - d. Provide a light sandblast finish after color hardener application has fully cured and set.
 - e. Coat concrete finish work with specified seal or approved equal, per manufacturer’s recommendation.”

By: 
Greg Smith,
Contract Administrator

Total number of pages contained within this Addendum: 3