



## ADDENDUM TO THE CONTRACT

for the

**Jensen-Olson Arboretum  
Sunroom Renovations  
Contract No. BE17-244**

**ADDENDUM NO.:** **FOUR**

**NEW DEADLINE FOR BIDS:**  
**September 29, 2017**

**PREVIOUS ADDENDA:** **THREE**

**ISSUED BY:** City and Borough of Juneau  
ENGINEERING DEPARTMENT  
155 South Seward Street  
Juneau, Alaska 99801

**PREVIOUS DEADLINE FOR BIDS:**  
**September 20, 2017**

**DATE ADDENDUM ISSUED:**

**September 19, 2017**

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: [http://www.juneau.org/engineering\\_ftp/contracts/Contracts.php](http://www.juneau.org/engineering_ftp/contracts/Contracts.php)

### **Bidder Questions:**

Question 1. *The concrete stairs are shown to be demolished and then wood stairs built to replace. This is going to leave a void under the stairs where the foundation wall will be seen. I see notes about patching the existing damaged rock work areas, but what about the area under the stairs? Is it to be infilled to match?*

Response 1. No.

### **Information Item:**

*78mg/Kg lead has been detected in the paint on the exterior siding. Test results for the exterior window trim paint is pending. Results and further direction to contractors anticipated to be issued September 22. See extension below of Deadline for Bids*

### **PROJECT MANUAL:**

Item No. 1 SECTION 00030 NOTICE INVITING BIDS, DEADLINE FOR BIDS. **Change** the date of the Deadline for Bids **from** September 20, 2017 **to** September 29, 2017. The time remains the same.

### **DRAWINGS:**

Item No. 1 Sheet A2, Drawing B - SUNROOM PLAN (NEW) **omit** one type B window on East wall. See Sheet A3, Drawing C – EAST ELEVATION for location of remaining type B window.

By:   
Greg Smith,  
Contract Administrator