



ADDENDUM TO THE CONTRACT

for the

**Bartlett Regional Hospital (BRH) Server Room
Fire Suppression System
Contract No. BE18-171**

ADDENDUM NO.: TWO

**CURRENT DEADLINE FOR BIDS:
March 7, 2018**

PREVIOUS ADDENDA: ONE

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: March 2, 2018

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

QUESTIONS AND CLARIFICATIONS:

- Item No. 1 Q: If 120V branch circuits are required for the fire suppression system or damper actuation what panel should they come from and where is that panel?
A: Life Safety Branch power shall be used for Fire Suppression System controls
- Item No. 2 Q: Is it acceptable for the shunt trip circuit to come from the "Normal" branch circuit power source or should it derive from the same power source as the fire suppression equipment?
A: The shunt trip circuit requirements shall be coordinated with the fire suppression system provider. It is considered part of the Fire Suppression System controls.
- Item No. 3 Q: What level of coordination will be required for de-energizing circuit in panel N22E1? We will need to do this to make room for a shunt trip breaker?
A: This shall be coordinated with the BRH maintenance staff.

DRAWINGS:

- Item No. 1 Drawing E1 Enlarged Computer 2425 & Electrical 1131 Plans, **Add** General Project Note 8 as follows: Utilize Life Safety Branch power where additional circuits are required. A circuit from Panel LS22D1, located in Electrical Room 2564, adjacent to Comms 2563 may be used to power Fire Suppression equipment.

By: 

Greg Smith,

Contract Administrator

Total number of pages contained within this Addendum: 1