



ADDENDUM TO THE CONTRACT

for the

**Lee Street Pump Station Renovation
Contract No. BE-19-250**

ADDENDUM NO.: FIVE

**CURRENT DEADLINE FOR BIDS:
July 10, 2019**

PREVIOUS ADDENDA: FOUR

ISSUED BY: City and Borough of Juneau
ENGINEERING DEPARTMENT
155 South Seward Street
Juneau, Alaska 99801

DATE ADDENDUM ISSUED: July 8, 2019

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Engineering Contracts Division webpage at: <http://www.juneau.org/engineering ftp/contracts/Contracts.php>

CLARIFICATIONS:

Question: "Can you please provide specifications on the 6" flow meter? None were found in the plans or specs."

Response: Specifications for the flow meter and transmitter are included in:

Section 262945 – Industrial Controls and Sensors, Part 3 – Products, 2.3 Water Pressure Transmitter

Section 262945 – Industrial Controls and Sensors, Part 3 – Products, 2.4 Water Flow – Magnetic Sensor

PROJECT MANUAL:

- Item No. 1 SECTION 262923 – VARIABLE FREQUENCY MOTOR CONTROLLERS; PART 2 – PRODUCTS; 2.1 MANUFACTURERS
- A. Subject to compliance with requirements, provide products by the following:
1. Rockwell Automation, Inc.; Allen-Bradley Brand. **Add** "No Substitute."

By: 
Greg Smith,
Contract Administrator

Total number of pages contained within this Addendum: 1