



Capital City Fire/Rescue

Fire Marshal's Office

820 Glacier Avenue Juneau, Alaska
99801

Business (907) 586-5322
Fax (907) 586-8323

Readiness, Dedication, Service

PRE-INSPECTION CHECKLIST- please complete the week before inspection.

Exits

- Are exit signs illuminated and working properly?
- Is emergency exit lighting working properly?
- Are all exits maintained and accessible?
- Are the exits clear with no obstructions?
- Do doors swing easily?
- Are all exit hardware working easily?
- Is all emergency lighting working?
- All exit doors shall not have decorations on the door.

General

- Are the top of portable fire extinguishers weighing less than 40lbs hung no more than 5' off the ground and accessible? (Weight over 40lbs hung no more than 3.5' off the top of the ground)
- Is access to the portable fire extinguisher free of obstruction?
- Is wiring safe and in good condition throughout the building?
- Are all cover plates intact on outlets, light switches and any junction boxes?
- Is storage height being maintained a minimum of 24" below ceiling in buildings without fire sprinklers or 18" below ceiling in building with fire sprinklers?
- Are surge protectors plugged directly into the wall not interconnected or used with extension cords?
- Are all ceiling tiles in place and there are no openings into attic space or area above the ceiling?

- Are multi-plug adapters being used? (Multi-plug adapters, such as cube adapters, unfused plug strips etc.)

Fire protection systems and equipment.

- Is the Fire Alarm System serviced and tagged within the past 12 months?
- Is the phone number to the alarm company posted on the panel?
- Is the Fire Alarm System clearly identified with no trouble light showing?
- Are all fire alarm pull stations clear and unobstructed?
- Is the Fire Sprinkler System serviced and tagged within the past 12 months?
- Are all fire sprinkler risers accessible, and if enclosed, are rooms clearly labeled?
- Are commercial kitchen hood extinguishing systems serviced and tagged within the past 12 months?
- Have kitchen hoods been cleaned recently & are they free of grease accumulation?
- Have all Fire Extinguishers been serviced and tagged within the last 12 months?

Maintenance/Custodial Closets, Rooms or Shops

- *Are oil and paint rags stored in a metal container with a self-closing and tight-fitting lid?*
- *Is storage neat and orderly?*

Boiler/Mechanical/Electrical Rooms

- Is all storage cleared from these rooms?
- Are rooms clearly marked as to their purpose/use? (Fire alarm, electrical room)
- Are all fire rated assemblies in working condition? (self-closing doors working, no penetrations in fire rated walls)
- Are electrical subpanels clear of decoration & obstruction? A working space of not less than 30" in width, 36" in depth, and 78" in height shall be provided in front of electrical service equipment.